



DEPARTMENT OF THE AIR FORCE

HEADQUARTERS 49TH FIGHTER WING (ACC)
HOLLOMAN AIR FORCE BASE, NEW MEXICO

*File
E HARRIS
12/2/92*

05 JUN 1992

FROM: 49 CES/CEV
Holloman AFB, NM 88330-5000

SUBJ: Repair to Treatment, Storage, Disposal Facility (TSDF)

TO: State of New Mexico
Environmental Department
ATTN: Stephanie Stoddard
1190 St. Francis Drive
Santa Fe, NM 87503

1. On Friday, 29 May, the faucet tied to the emergency eye wash and shower in our TSDF was broken. We phoned your office with this information on the same day. Per your request, this letter is to inform you of our planned corrective action.
2. The water to the TSDF has been shut off and operations in the facility have been restricted until repairs have been made. The repairs are scheduled to start on 5 June. Since concrete will have to be removed to make repairs, a jackhammer will be necessary. All flammables will be removed and stored outside the TSD on the concrete pad during the repairs. If the repairs take more than one day, the flammables will be moved back inside at night.
3. Care will be taken to seal the joints between old and new concrete.
4. Our Safety Officer and the Bioenvironmental Office are aware of the situation and concur with our plan of action. If your office has any concerns regarding this event, please contact Valerie Stacey at 479-3931.

Howard E. Moffitt
HOWARD E. MOFFITT
Deputy Base Civil Engineer

