



BRUCE KING
GOVERNOR

State of New Mexico
ENVIRONMENT DEPARTMENT
Harold Runnels Building
1190 St. Francis Drive, P.O. Box 26110
Santa Fe, New Mexico 87502
(505) 827-2850



ENTERED

JUDITH M. ESPINOSA
SECRETARY

RON CURRY
DEPUTY SECRETARY

June 18, 1992

Col. Thomas A. Norris
Director, Environmental Management Division
542 CTW/EM
Kirtland Air Force Base, NM 87117-5000

RE: Request for Determination on Treatment in Accumulation Tank.

Dear Col. Norris,

In reference to our discussions and correspondence regarding a tank that will be in place to collect and treat spilled hydrazine fuel, NMED has determined that this tank would fall under the treatment in accumulation tank rulings (Federal Register Vol. 51, No. 53, March 24, 1986), and would not be subject to specific permitting requirements. However, it is the facility's responsibility to manage this system in compliance with appropriate sections of 40 CFR section 264 to insure that human health and the environment are protected, and that its operation continues to fall under the treatment in accumulation tank exclusion.

If you have any further questions, please do not hesitate to call me.

Sincerely,

A handwritten signature in cursive script that reads "Herb Grover".

Herb Grover
RCRA Permit Supervisor

KAFB1226

