

**Public Service Company of New Mexico
Person Generating Station
Groundwater Treatment System**

**Treatment Effectiveness Report
First Quarter 1998**

May 13, 1998

Report Prepared Pursuant to Requirements Contained in:

**The Person Generating Station Corrective Action Directive (NMT 360010342)
and
The New Mexico Environment Department Discharge Plan, DP-1006**

Table of Contents

I. Introduction	1
II. Operational History	3
III. Groundwater Treatment Effectiveness	4
IV. Operational Activities	11
V. Influent / Effluent Flow Volumes	12
VI. Laboratory Analysis	14
A. Influent/Effluent Sampling for Chlorinated VOC's (8010 Analysis)	14
B. Effluent Sulfate Analysis and pH Monitoring	16
C. Golf Course Pond Sampling	16
VII. Groundwater Sampling	17

Appendix A. Laboratory Reports

List of Figures

Figure 1. Person Generating Station Site Map	2
Figure 2. Total VOCs at PSMW-16	4
Figure 3. Total VOCs at the VEW	5
Figure 4. Total VOCs at EW-1	5
Figure 5. Total VOCs at PSMW-24, 25, 26	6
Figure 6. Total VOCs GTS Influent vs. Effluent	14
Figure 7. Concentration of PCE in Groundwater	18
Figure 8. Concentration of DCE in Groundwater	19
Figure 9. Concentration of TCA in Groundwater	20

List of Tables


Table 1. Influent Concentrations at PSMW-16	7
Table 2. Influent Concentrations at VEW	8
Table 3. Influent Concentrations at EW-1	9
Table 4. Combined Influent Concentrations at PSMW-24, 25, and 26	10
Table 5. Influent and Effluent Flow Volumes	13
Table 6. Influent and Effluent VOC Concentrations	15
Table 7. GTS Effluent Sulfate Concentrations	16
Table 8. Monthly pH Readings	16

I. Introduction

This report is prepared pursuant to requirements contained in the Person Generating Station Corrective Action Directive (NMT360010342) issued by the New Mexico Environment Department (NMED) Hazardous and Radioactive Materials Bureau, and requirements contained in Discharge Plan DP-1006 issued by the NMED Groundwater Protection and Remediation Bureau.

This report contains information on sampling results and operational activities at the Person Generating Station Groundwater Treatment System (GTS). The GTS is designed to extract volatile organic compound contaminated groundwater, treat through an air stripper and granular activated carbon filter, and discharge the treated water to an irrigation pond at the UNM Championship Golf Course.

Figure 1 is a site map of the Person Generating Station vicinity and shows well locations and the location of the pipeline system.



LEGEND	
	GROUNDWATER PUMPING WELL
	MONITORING WELL
	PRODUCTION WELL (SEALED)
	ROADS
	PROPERTY LINES

SITE MAP

Public Service Company of New Mexico
Person Generating Station
Albuquerque, New Mexico

PARSONS ENGINEERING SCIENCE, INC.
Denver, Colorado