

Public Service Company
of New Mexico
Alvarado Square MS 0408
Albuquerque, NM 87158

November 10, 1998


Certified Mail
Return Receipt Requested

Mr. Benito Garcia
Executive Director
Chief, Hazardous and Radioactive
Materials Bureau
New Mexico Environment Department
P.O. Box 26110
Santa Fe, NM 87502

Dear Mr. Garcia:

**Subject: Treatment Effectiveness Report, Third
Quarter 1998, Groundwater Treatment
System, Person Generating Station,
NMT 360010342**

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.



Toni Ristau

Director, Environmental Services

Enclosed please find three copies of the subject report submitted pursuant to requirements contained in the Person Station Corrective Action Directive issued in September 1991.

If you have any questions, please contact me at (505) 241-2014.

Sincerely,



John Hale
Environmental Engineer

enclosure



Steph

**Public Service Company of New Mexico
Person Generating Station
Groundwater Treatment System**

**Treatment Effectiveness Report
Third Quarter 1998**

November 10, 1998

Report Prepared Pursuant to Requirements Contained in:

**The Person Generating Station Corrective Action Directive (NMT 360010342)
and
The New Mexico Environment Department Discharge Plan, DP-1006**

Table of Contents

Executive Summary	1
I. Introduction	2
II. Operational History	4
III. Groundwater Treatment Effectiveness	5
IV. Operational Activities	12
V. Influent and Effluent Flow Volumes	13
VI. Laboratory Analysis	15
A. Influent and Effluent Sampling for Chlorinated VOC's (8021 Analysis)	15
B. Effluent Sulfate Analysis and pH Monitoring	17
C. Golf Course Pond Sampling	17
VII. Groundwater Sampling	18

Appendix A. Laboratory Reports

List of Figures

Figure 1. Person Generating Station Site Map	3
Figure 2. Total VOCs at PSMW-16	6
Figure 3. Total VOCs at the VEW	6
Figure 4. Total VOCs at EW-1	7
Figure 5. Total VOCs at PSMW-24, 25, 26	7
Figure 6. Total VOCs GTS Influent vs. Effluent	15
Figure 7. Concentration of PCE in Groundwater	19
Figure 8. Concentration of DCE in Groundwater	20
Figure 9. Concentration of TCA in Groundwater	21

List of Tables

Table 1. Influent Concentrations at PSMW-16	8
Table 2. Influent Concentrations at VEW	9
Table 3. Influent Concentrations at EW-1	10
Table 4. Combined Influent Concentrations at PSMW-24, 25, and 26	11
Table 5. Influent and Effluent Flow Volumes	14
Table 6. Influent and Effluent VOC Concentrations	16
Table 7. GTS Effluent Sulfate Concentrations	17
Table 8. Monthly pH Readings	17

Executive Summary

Contour maps for PCE, DCE, and TCA for the spring sampling event are shown in figures 7, 8, and 9, respectively. These figures indicate a continued reduction in the size of the contaminant plume as well as a decrease in the concentrations of these contaminants in the groundwater over the operational period of the GTS.


Operational problems with the air stripper pump caused the GTS to be off-line during most of July. Consequently, the total volume of treated effluent pumped to the UNM Championship Golf Course was significantly reduced this quarter.

I. Introduction

This report is prepared pursuant to requirements contained in the Person Generating Station Corrective Action Directive (NMT360010342) issued by the New Mexico Environment Department (NMED) Hazardous and Radioactive Materials Bureau, and requirements contained in Discharge Plan DP-1006 issued by the NMED Groundwater Protection and Remediation Bureau.

This report contains information on sampling results and operational activities at the Person Generating Station Groundwater Treatment System (GTS). The GTS is designed to extract volatile organic compound contaminated groundwater, treat through an air stripper and granular activated carbon filter, and discharge the treated water to an irrigation pond at the UNM Championship Golf Course.

Figure 1 is a site map of the Person Generating Station vicinity and shows well locations and the location of the pipeline system.



LEGEND	
	GROUNDWATER PUMPING WELL
	MONITORING WELL
	PRODUCTION WELL (SEALED)
	ROADS
	PROPERTY LINES

SITE MAP

Public Service Company of New Mexico
Person Generating Station
Albuquerque, New Mexico

PARSONS ENGINEERING SCIENCE, INC.
Denver, Colorado

II. Operational History

The GTS was started on Friday, January 27, 1995, with treated effluent being sent to the UNM Championship Golf Course.

During 1995, the GTS encountered periodic minor problems as well as a more serious problem with mineralization of the system components downstream from the air stripper. The GTS was kept off-line for most of the first quarter of 1996 while the mineralization problem was studied. After evaluation of various treatment methods, an acid treatment system was selected as the most feasible solution to the mineralization problem.

Installation of the acid treatment system began in early May 1996. In early April, construction activities were initiated to convert monitor wells PSMW-24, PSMW-25, and PSMW-26 (PSMW-24, 25, and 26) to extraction wells. The GTS resumed regular operation in mid-June 1996.

The Person Generating Station Discharge Plan, DP-1006, was amended and approved by the Groundwater Protection and Remediation Bureau in mid-June 1997. As part of the amended plan, the existing plan requirement for the sulfuric acid treatment system was replaced. Previously, acid addition to the effluent was restricted to 35 mg/l. The new requirement specifies adjustment of the acid treatment system to maintain an effluent pH range of 6.0 to 9.0. A pH probe and chart recorder were installed on the effluent discharge tank for daily monitoring of pH, and effluent samples are collected monthly for total sulfate analysis.

During the third quarter, the GTS was off-line for much of July due to operational problems with both of the dual treatment train's air stripper pumps.

III. Groundwater Treatment Effectiveness

Figures 2, 3, and 4 show graphs of concentration of total chlorinated VOC's as measured at wells PSMW-16, VEW, and EW-1 over the operational period of the GTS. Figure 5 shows a graph of concentration of total chlorinated VOC's in the combined influent from wells PSMW-24, 25, and 26 over the operational period of the GTS. More detailed data for these wells are shown in Tables 1, 2, 3, and 4.

During the first quarter of 1998, total chlorinated VOC's increased slightly at EW-1. Total chlorinated VOC's fluctuated during the first quarter in the combined influent from wells PSMW-24, 25, and 26. During March 1998, PSMW-16 and VEW were redeveloped. Therefore, no samples were collected from these wells in March. Prior to redevelopment activities total chlorinated VOC's had been relatively constant at these wells.

Beginning in January 1998, EPA Method 8021 (Halo) replaced EPA Method 8010. Therefore, all first quarter groundwater samples were analyzed with the 8021 (Halo) method.

During the second quarter of 1998, total chlorinated VOC's increased slightly at the VEW. In April, a decrease in total chlorinated VOC's was noted at PSMW-16 and in the combined influent from PSMW-24, 25, and 26. However, for the remainder of the second quarter, total chlorinated VOC's have fluctuated at these wells. EW-1 showed a decrease in total chlorinated VOC's during the second quarter.

A slight rebound effect was observed at PSMW-16 during the third quarter. This increase and subsequent decrease in total chlorinated VOC's is thought to be due to the GTS being off-line during July and restarted in August. Recent analytical data indicates that PSMW-16 has higher concentrations of total chlorinated VOC's than the other extraction wells. Data analysis indicates that a plug or hot spot of higher concentration contaminants in the groundwater is moving towards PSMW-16. Thus, the rebound effect is much more noticeable at this extraction well.

Total chlorinated VOC's fluctuated slightly at the VEW during this quarter. In the combined influent from PSMW-24, 25, and 26, total chlorinated VOC's dropped during this quarter. At EW-1, a sharp decrease in total chlorinated VOC's occurred between the August and September sampling events. The cause of this sharp decrease is unknown.

Laboratory reports for this quarter are contained in appendix A.

Figure 2
Total VOCs at PSMW-16




Figure 3
Total VOCs at the VEW




Figure 4
Total VOCs at EW-1




Figure 5
Total VOCs at PSMW-24,25,26




Table 1
Influent Concentrations at PSMW-16

Date	Laboratory Report No.	PCE (ppb)	DCE (ppb)	Total VOC's (ppb)
2/1/95	502304	200	110	31004
2/15/95	502376	69	39	115.0
3/8/95	503317	78	46	128.3
4/10/95	504341	170	81	258.6
5/18/95	505371	62	30	94.6
6/21/95	506396	76	36	114.8
7/12/95	507327	75	41	124.3
8/17/95	508405	83	45	134.0
9/13/95	509339	69	35	109.2
10/11/95	510335	66	32	102.8
11/22/95	511367	58	35	97.5
3/20/96	603347	180	63	245.3
4/17/96	604367	110	46	162.5
7/18/96	607334	120	54	182.9
8/15/96	608331	120	51	179.1
9/18/96	609338	110	43	160.9
10/16/96	610361	97	37	140.0
11/19/96	611331	94	42	141.0
12/17/96	612331	96	39	140.0
1/16/97	701336	99	46	150.7
2/13/97	702332	100	40	143.7
3/19/97	703344	88	23	114.6
4/17/97	704355	93	38	135.8
5/15/97	705347	71	32	107.6
6/18/97	706353	83	36	122.6
7/23/97	707360	67	34	103.1
9/15/97	709332	100	34	137.9
10/15/97	710358	92	31	127.2
11/19/97	711335	95	34	134.5
12/16/97	712318	140	68	208
1/15/98	801334	110	37	153.1
2/11/98	802336	110	38	155.3
3/11/98	NA	NA	NA	NA
4/8/98	804337	78	30	114.4
5/20/98	805379	67	23	93.4
6/16/98	806353	89	30	124.6
7/1/98	807300	76	29	108.8
8/13/98	808040	120	41	168.5
9/16/98	809042	110	26	140.7

Table 2
Influent Concentrations at VEW

Date	Laboratory Report No.	PCE (ppb)	DCE (ppb)	Total VOC's (ppb)
2/1/95	502304	5.3	0.8	6.1
2/15/95	502376	4	0.5	4.5
3/8/95	503317	1.5	0.3	1.8
4/10/95	504341	21	5.8	28.1
5/18/95	505371	1.4	<0.2	1.4
6/21/95	506396	25	9.4	39.8
7/12/95	507327	3.5	1.0	5.8
8/17/95	508405	6.4	1.1	17.7
9/13/95	509405	9.7	1.9	12.9
10/11/95	510335	9.3	1.8	12.5
11/22/95	511367	4.6	1.1	6.0
3/20/96	603347	270	72	344.3
4/17/96	604367	94	24	131.2
7/18/96	607334	47	14	70.6
8/15/96	608331	5.0	2.1	15.2
9/18/96	609338	3.1	2.1	15.8
10/16/96	610361	3.2	2.1	15.3
11/19/96	611331	0.8	1.8	13.6
12/17/96	612331	<0.5	2.0	15.0
1/16/97	701336	0.9	3.2	20.2
2/13/97	702332	1.0	2.4	19.2
3/19/97	703344	68	17	99.5
4/17/97	704355	2.8	3.4	24.4
5/15/97	705347	6.1	5.3	28.5
6/18/97	706353	3.8	4.2	23.5
7/23/97	707360	2.9	4.0	23.6
8/13/97	708339	57	50	124.8
9/15/97	709332	1.7	3.4	19.8
10/15/97	710358	3.2	3.1	20.5
11/19/97	711335	1.3	3.2	18.7
12/16/97	712318	1	4.8	21.7
1/15/98	801334	2.5	3.6	21.3
2/11/98	802336	2.9	3.7	22
3/11/98	NA	NA	NA	NA
4/8/98	804337	6.4	5.0	23.7
5/20/98	805379	8.4	5.4	24.3
6/16/98	806353	11	6.2	29.1
7/1/98	807300	7.6	4.6	25.0
8/13/98	808040	5.6	3.8	18.2
9/16/98	809042	8.9	5.6	25.3

Table 3
Influent Concentrations at EW-1

Date	Laboratory Report No.	PCE (ppb)	DCE(ppb)	Total VOC's (ppb)
8/17/95	508405	3.5	0.9	5.4
9/13/95	509339	25	6.1	33.6
10/11/95	510335	49	8.8	61.4
11/22/95	511367	38	9.5	51.3
7/18/96	607334	20	5.7	28.2
8/15/96	608331	45	8.4	57.0
9/18/96	609338	37	7.8	48.8
10/16/96	610361	29	7.3	40.6
11/19/96	611331	32	7.0	43.2
12/17/96	612331	33	7.7	46.4
1/16/97	701336	36	9.2	51.6
2/13/97	702332	32	7.7	47.9
3/19/97	703344	29	5.7	42.7
4/17/97	704355	31	8.4	52.5
5/15/97	705347	27	9.7	50
6/18/97	706353	23	8.6	49.4
7/23/97	707360	25	9.5	51.9
8/13/97	708339	20	6.8	45.8
9/15/97	709332	21	8.5	49.7
10/15/97	710358	18	6.5	45
11/19/97	711335	20	9.7	52.1
12/16/97	712318	21	12	58
1/15/98	801334	20	11	58.5
2/11/98	802336	21	11	59.7
3/11/98	803324	20	16	62.7
4/8/98	804337	16	9.7	46.8
5/20/98	805379	16	9	43.5
6/16/98	806353	13	7.9	40.8
7/1/98	807300	12	7.7	40.7
8/13/98	808040	8.5	7	36.4
9/16/98	809042	3.2	2.7	7.4

Table 4
Combined Influent Concentrations at PSMW-24, 25, and 26

Date	Laboratory Report No.	PCE (ppb)	DCE(ppb)	Total VOC's (ppb)
7/18/96	607334	49	55	110.6
8/15/96	608331	47	50	111.3
9/18/96	609338	58	44	106.3
10/16/96	610361	41	40	86.8
11/19/96	611331	46	44	95.2
12/17/96	612331	33	30	66.7
1/16/97	701336	41	41	86.5
2/13/97	702332	41	37	81.5
3/19/97	703344	37	23	63.0
4/17/97	704355	42	37	83.8
5/15/97	705347	33	30	66.4
6/18/97	706353	39	55	96.6
7/23/97	707360	37	36	75.2
8/13/97	708339	39	30	71.5
9/15/97	709332	42	34	78.4
10/15/97	710358	48	29	79.8
11/19/97	711335	41	34	77.5
12/16/97	712318	40	47	87
1/15/98	801334	33	25	60.6
2/11/98	802336	36	27	65.7
3/11/98	803324	30	31	63.4
4/8/98	804337	21	18	41
5/20/98	805379	18	12	31.1
6/16/98	806353	21	15	37.3
7/1/98	807300	18	16	35.2
8/13/98	808040	14	13	28.6
9/16/98	809042	6.5	4.4	27.9

IV. Operational Activities

The GTS was off-line for most of July due to operational problems with both of the dual treatment train's air stripper pumps. In addition, operational problems with the pump caused PSMW-24 to remain off-line for all of September.

V. Influent and Effluent Flow Volumes

Flow totalizing meters are present on each influent well line and on the effluent flow line. Table 5 below details flow volumes from each influent well and the effluent line. Differences between total influent and total effluent may be attributed to water loss (evaporation) out the stack in the air stripper system and to differences, inaccuracies, and operational problems with the flow meters.

**Table 5
Influent and Effluent Flow Volumes**


Source	Meter Number	Start Reading	End Reading	Volume (Gallons)
Flow Volumes for July 1998:				
Influent (VEW)	Badger Meter No. 94976130	3,513,484	3,515,028	1,544
Influent (PSMW-16)	Hayes Meter No. 29408700	5,244,400	5,249,771	5,371
Influent (EW-1)	Hayes Meter No. 29408732	4,195,924	4,199,639	3,715
Influent (PSMW-24)	Fisher Porter Meter No. 960307112	4,113,660	4,116,810	3,150
Influent (PSMW-25)	Fisher Porter Meter No. 960307112	1,078,750	1,081,320	2,570
Influent (PSMW-26)	Fisher Porter Meter No. 960307112	2,008,750	2,010,680	1,930
Effluent (to Golf Course)	Fisher Porter Meter No. 960307112	14,777,841	14,796,213	18,372
Flow Volumes for August 1998:				
Influent (VEW)	Badger Meter No. 94976130	3,515,028	3,538,094	23,066
Influent (PSMW-16)	Hayes Meter No. 29408700	5,249,771	5,331,818	82,047
Influent (EW-1)	Hayes Meter No. 29408732	4,199,639	4,266,220	66,581
Influent (PSMW-24)	Fisher Porter Meter No. 960307112	4,116,810	4,166,430	49,620
Influent (PSMW-25)	Fisher Porter Meter No. 960307112	1,081,320	1,120,140	38,820
Influent (PSMW-26)	Fisher Porter Meter No. 960307112	2,010,680	2,041,020	30,340
Effluent (to Golf Course)	Fisher Porter Meter No. 960307112	14,796,213	15,081,620	285,407
Flow Volumes for September 1998:				
Influent (VEW)	Badger Meter No. 94976130	3,538,094	3,581,387	43,293
Influent (PSMW-16)	Hayes Meter No. 29408700	5,331,818	5,487,476	155,658
Influent (EW-1)	Hayes Meter No. 29408732	4,266,220	4,404,091	137,871
Influent (PSMW-24)	Fisher Porter Meter No. 960307112	4,166,430	4,166,430	0
Influent (PSMW-25)	Fisher Porter Meter No. 960307112	1,120,140	1,192,340	72,200
Influent (PSMW-26)	Fisher Porter Meter No. 960307112	2,041,020	2,100,980	59,960
Effluent (to Golf Course)	Fisher Porter Meter No. 960307112	15,081,620	15,540,925	459,305
Quarterly Total for Influent (VEW+PSMW-16+EW-1+PSMW-24+PSMW-25+PSMW-26)				763,084
Quarterly Total for Effluent:				777,736
Annual Totals				
Annual Cumulative Influent Total for 1998:				5,062,982
Annual Cumulative Effluent Total for 1998:				5,009,679

VI. Laboratory Analysis

A. Influent and Effluent Sampling for Chlorinated VOC's (8021 Analysis)

During the third quarter, influent and effluent sampling was conducted pursuant to the routine schedule outlined in DP-1006, i.e., once each month. Chlorinated VOC analysis of GTS influent and effluent (after GAC units) is shown graphically in figure 6. More detailed data are shown in table 6 below. Laboratory analytical data reports are contained in appendix A. All influent and effluent sampling results indicate that the GTS has consistently removed chlorinated VOC contaminants in the 50 to 200 ppb range to levels below laboratory detection limits in the effluent sent to the golf course. Laboratory analysis of the water at a point after the air stripper and before the granular activated carbon treatment also show that at these influent concentrations and a flow rate of approximately 20 to 25 gpm, the air stripper alone is capable of treating the groundwater to concentrations consistently below or near laboratory detection limits for chlorinated VOC's.

Figure 6
Total VOCs GTS Influent vs. Effluent



**Table 6
Influent and Effluent VOC Concentrations**

Sampling Date: 7/1/98	Lab Report Number: 807300		
VOC Compound	Influent (ppb)	Effluent After Air Stripper (ppb)	Effluent After GAC Unit (ppb)
Chloroform	0.8	< 0.5	< 0.5
1,1-Dichloroethane	1.3	< 0.3	< 0.3
1,1-Dichloroethene	9.7	< 0.2	< 0.2
Tetrachloroethene	21	< 0.5	< 0.5
1,1,1-Trichloroethane	3.0	< 1.0	< 1.0
TOTAL VOC'S	35.8	BDL	BDL

Sampling Date: 8/13/98	Lab Report Number: 808040		
VOC Compound	Influent (ppb)	Effluent After Air Stripper (ppb)	Effluent After GAC Unit (ppb)
Chloroform	1.1	< 0.5	< 0.5
1,1-Dichloroethane	1.8	< 0.3	< 0.3
1,1-Dichloroethene	13	< 0.2	< 0.2
Tetrachloroethene	32	< 0.5	< 0.5
1,1,1-Trichloroethane	2.6	< 1.0	< 1.0
TOTAL VOC'S	50.5	BDL	BDL

Sampling Date: 9/16/98	Lab Report Number: 809042		
VOC Compound	Influent (ppb)	Effluent After Air Stripper (ppb)	Effluent After GAC Unit (ppb)
Chloroform	0.7	< 0.5	< 0.5
1,1-Dichloroethane	1.6	< 0.3	< 0.3
1,1-Dichloroethene	5.7	< 0.2	< 0.2
Tetrachloroethene	25	< 0.5	< 0.5
1,1,1-Trichloroethane	2.3	< 1.0	< 1.0
TOTAL VOC'S	35.3	BDL	BDL

B. Effluent Sulfate Analysis and pH Monitoring

The June 1997 amendment to DP-1006 requires monthly sulfate analysis and daily pH monitoring of the GTS effluent. Table 7 presents the results of the third quarter sulfate analysis using EPA Method 375.4. The monthly minimum, maximum, and average pH readings for this quarter are shown in table 8. The monthly readings for August were unavailable at the time this report was prepared.

Table 7
GTS Effluent Sulfate Concentrations

Date	Lab Report Number	Sulfate (Mg/l)
7/1/98	807300	440
8/13/98	808040	380
9/16/98	809042	470

Table 8
Monthly pH Readings

Date	Minimum pH	Maximum pH	Average pH
7/98	6.8	7.8	7.6
8/98	NA	NA	NA
9/98	6.3	7.1	6.9

C. Golf Course Pond Sampling

DP-1006 requires monthly sampling of the east and west ponds for 8021 (Halo) analysis during each month of operation. During the third quarter, the ponds were sampled three times pursuant to this requirement. No EPA Method 8021 (Halo) parameters were detected in the samples. Copies of the laboratory reports are contained in appendix A.

VII. Groundwater Sampling

Under the RCRA permit, a network of groundwater monitoring wells are sampled on a twice per year schedule (normally in the spring and fall). Once sampling is complete and analytical results have been received, contour maps showing the distribution of the contaminants in the groundwater are prepared. Contour maps for PCE, DCE, and TCA for the spring sampling event are shown in Figures 7, 8, and 9, respectively.