


file Sparton
SPARTON

SPARTON TECHNOLOGY

February 22, 1996



Technical Section (6H-CD)
RCRA Enforcement Branch
Hazardous Waste Management Division
U.S. Environmental Protection Agency
1445 Ross Avenue
Dallas, Texas 75202-2733

Attention: Mr. Ronald Crossland
Reference: Monthly Report
Sparton Technology, Inc.

Gentlemen:

This is the monthly progress report for Sparton Technology, Inc.'s Coors Road Facility, located in Albuquerque, New Mexico, as required in Section IV.C of the Consent Order. This report summarizes activities performed at the site during the month of January 1996

Site Activities

1. Air stripper removal efficiencies continue to average about 99 percent for the measured indicator parameters. During the month, 26,100 gallons of recovered groundwater were treated, bringing the total volume treated to date to 3,536,900 gallons. Air stripper performance data is included in Attachment 1.

002880

February 22, 1996
Technical Section (6H-CD)
RCRA Enforcement Branch
Hazardous Waste Management Division
U.S. Environmental Protection Agency
Page 2

This concludes our progress report for the month of January 1996. If you have any questions, please contact the undersigned.

Very truly yours,

SPARTON TECHNOLOGY, INC.

for 

Richard D. Mico
Vice President/General Manager

Attachments: (as stated)

cc: NMED
J. Appel
P. Chandler
J. Wakefield
G. Richardson

002881

ATTACHMENT 1

Air Stripper Performance Data

002882

AIR STRIPPER PERFORMANCE

Sparton Technology, Inc.
Albuquerque, New Mexico

(all concentrations in micrograms per liter (ppb))

DATE SAMPLED	1,1-Dichloroethylene [-----]			Methylene Chloride [-----]			1,1,1-Trichloroethane [-----]			Trichloroethylene [-----]		
	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION
12/12/88	21	0.32	98.5	293	5.4	98.2	95	1.9	98.0	328	6.3	98.1
12/14/88	170	1.1	99.4	2230	26.5	98.8	1090	9.7	99.1	2490	22.4	99.1
12/19/88	87	0.4	99.5	1320	13.6	99.0	862	6.0	99.3	2200	14.8	99.3
12/27/88	89	0.5	99.4	1250	2.4	99.8	648	3.3	99.5	1300	7.2	99.4
01/06/89	64	0.2	99.7	581	3.3	99.4	340	1.7	99.5	712	4.1	99.4
01/23/89	82	0.2	99.8	545	7.4	98.6	570	2.6	99.5	1220	7.5	99.4
02/02/89	83	0.3	99.6	514	0.1	100.0	389	2.2	99.4	1550	8.6	99.4
03/06/89	107	1.5	98.6	38	0.4	98.9	708	11.0	98.4	1300	21.0	98.4
04/03/89	79	1	98.7	84	1	98.9	371	0	99.7	880	1.5	99.8
05/01/89	94	1	98.9	14	1	92.9	243	0	99.6	632	1	99.8
06/05/89	28	1	96.4	148	1	99.3	198	0	99.5	685	1	99.9
07/05/89	20	0.1	99.5	2.4	0.1	95.8	154	0.1	99.9	452	0.14	100.0
08/07/89	27	0.1	99.6	2.4	0.1	95.8	152	0.18	99.9	477	0.19	100.0
09/05/89	53	0.1	99.8	8.5	0.1	98.8	310	0.1	100.0	785	0.2	100.0
10/02/89	62	0.1	99.8	2.6	0.1	96.2	286	0.1	100.0	905	0.1	100.0
11/06/89	20.9	0.1	99.5	140.0	0.3	99.8	87.5	0.1	99.9	392	0.25	99.9
12/04/89	23.0	0.1	99.6	131.0	0.2	99.8	71	0.1	99.9	378	0.40	99.9
01/08/90	19.7	0.1	99.5	140.0	0.4	99.7	90.3	0.18	99.8	359	0.91	99.7
02/05/90	34.0	0.1	99.7	44.0	0.2	99.5	250	0.47	99.8	670	1.8	99.7
03/05/90	45.0	0.1	99.8	35.0	0.2	99.4	240	0.19	99.9	780	0.91	99.9
04/02/90	64.0	0.1	99.8	10.0	0.4	96.0	310	0.1	100.0	1300	0.32	100.0
05/07/90	43.0	0.1	99.8	8.7	0.1	98.9	190	0.1	99.9	720	0.18	100.0
06/04/90	70.0	0.1	99.9	1.0	0.1	90.0	180	0.1	99.9	820	0.1	100.0
07/02/90	30.0	0.1	99.7	1.0	1.0	----	140	0.1	99.9	625	0.1	100.0
08/06/90	40.0	0.1	99.8	21.0	0.1	99.5	140	0.1	99.9	550	0.59	99.9
09/10/90	44.0	0.1	99.8	5.9	0.1	98.3	150	1.0	99.9	880	1.0	99.9
10/01/90	93.0	1.0	98.9	6.7	1.0	85.1	290	1.0	99.7	1200	1.0	99.9
11/05/90	64.0	1.0	98.4	10.0	1.0	90.0	200	1.0	99.5	1200	1.0	99.9
12/19/90	26.0	1.0	96.2	1.0	1.0	----	120	1.0	99.2	460	1.0	99.8
01/08/91	68.0	1.0	98.5	22.0	1.0	95.5	490	1.0	99.8	1620	3.5	99.8
02/04/91	82.0	1.0	98.8	1.0	1.0	----	396	1.0	99.7	1500	1.6	99.9
03/18/91	330.0	1.0	99.7	1.0	1.0	----	210	1.0	99.5	550	1.0	99.8

002883

AIR STRIPPER PERFORMANCE
(CONTINUED)

Sparton Technology, Inc.
Albuquerque, New Mexico

(all concentrations in micrograms per liter (ppb))

DATE SAMPLED	1,1-Dichloroethylene [-----]			Methylene Chloride [-----]			1,1,1-Trichloroethane [-----]			Trichloroethylene [-----]		
	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION
04/01/91	72.0	1.0	98.6	1.0	1.0	----	150.0	1.0	----	820.0	1.0	99.9
05/06/91	22.0	1.0	95.5	1.0	1.0	----	140.0	1.0	99.3	770.0	1.0	99.9
06/03/91	180.0	1.0	99.4	31.0	1.0	96.8	620.0	1.0	99.8	2100.0	1.7	99.9
06/30/91	41.0	1.0	97.6	1.0	1.0	----	110.0	1.0	99.1	360.0	1.2	99.7
08/02/91	88.0	1.0	98.9	5.0	1.0	80.0	340.0	1.0	99.7	1200.0	1.0	99.9
09/09/91	10.0	1.0	90.0	10.0	1.0	90.0	390.0	1.0	99.7	1700.0	1.0	99.9
10/7/91	74.0	1.0	98.6	1.0	1.0	----	320.0	1.0	99.7	1100.0	1.0	99.9
11/04/91	130.0	1.0	99.2	1.0	1.0	----	290.0	1.0	99.7	1400.0	1.0	99.9
12/02/91	62.0	1.0	98.4	1.0	1.0	----	270.0	1.0	99.6	1000.0	1.0	99.9
01/06/92	100.0	1.0	99.0	1.0	1.0	----	250.0	1.0	99.6	2000.0	1.1	99.9
02/03/92	150.0	1.7	98.9	77.0	1.0	98.7	390.0	4.0	99.0	1900.0	1.3	99.9
03/02/92	160.0	1.0	99.4	4.9	1.0	79.6	420.0	1.0	99.8	1300.0	1.0	99.9
04/01/92	100.0	1.0	99.0	1.0	1.0	----	490.0	1.0	99.8	2800.0	1.0	100.0
05/06/92	35.0	1.0	97.1	2.0	1.0	50.0	210.0	1.0	99.5	1400.0	1.0	99.9
06/01/92	61.1	1.0	98.4	1.0	1.0	----	185.0	1.0	99.5	530.0	1.0	99.8
07/01/92	76.0	1.0	98.7	1.3	1.0	23.1	156.0	1.0	99.4	776.0	1.0	99.9
08/10/90	28.0	1.0	96.4	33.0	1.0	97.0	211.0	1.0	99.5	830.0	1.0	99.9
09/11/92	67.0	1.0	98.5	112.0	1.0	99.1	185.0	1.0	99.5	747.0	1.0	99.9
10/01/92	58.0	1.0	98.3	1.0	1.0	----	164.0	1.0	99.4	964.0	1.0	99.9
11/02/92	114.0	1.0	99.1	18.0	1.0	94.4	261.0	1.0	99.6	1140.0	1.0	99.9
12/01/92	70.0	1.0	98.6	1.0	1.0	----	194.0	1.0	99.5	875.0	1.0	99.9
01/04/93	74.0	1.0	98.6	24.0	1.0	95.8	220.0	1.9	99.1	1020.0	1.0	99.9
02/01/93	46.0	1.0	97.8	1.0	1.0	----	140.0	1.0	99.3	860.0	1.0	99.9
03/01/93	1.0	1.0	----	32B	1.0	96.9	180.0	1.0	99.4	1200.0	1.0	99.9
04/06/93	35.0	1.0	97.1	26B	1.0	96.2	120.0	1.0	99.2	630.0	3.8	99.4
05/05/93	30.0	1.0	96.7	56B	1.0	98.2	86.0	1.0	98.8	520.0	1.0	99.8
06/08/93	64.0	1.0	98.4	52B	1.0	98.1	161.0	1.0	99.4	710.0	1.0	99.9
07/12/93	18.0	1.0	94.4	13.0	1.0	92.3	140.0	6.7	95.2	750.0	39.0	94.8
08/13/93	37.0	1.0	97.3	1.0	1.0	----	150.0	1.0	99.3	840.0	1.0	99.9
08/13/93*	45.0	0.2	99.6	10.0	2.0	80.0	170.0	0.2	99.9	840.0	0.2	100.0
09/15/93	35.0	1.0	97.1	1.0	1.0	----	160.0	1.0	99.4	940.0	1.0	99.9
10/14/93	58.0	1.0	98.3	1.0	1.0	----	200.0	1.0	99.5	940.0	1.0	99.9

Note: Influent detection limits for 08/02/81 and 09/09/91 are 5.0 ug/l and 10.0 ug/l, respectively which is higher than previous detection limits.
B indicates analyte was detected in the laboratory blank.

*: Duplicate analysis

002284

AIR STRIPPER PERFORMANCE
(CONTINUED)
Sparton Technology, Inc.
Albuquerque, New Mexico

(all concentrations in micrograms per liter (ppb))

DATE SAMPLED	1,1-Dichloroethylene [-----]			Methylene Chloride [-----]			1,1,1-Trichloroethane [-----]			Trichloroethylene [-----]		
	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION
11/03/93	88.0	1.0	98.9	49.0	1.0	98.0	280.0	1.0	99.6	1400.0	1.2	99.9
12/20/93	42.0	1.0	97.6	1.0	1.0	----	170.0	1.0	99.4	1000.0	1.0	99.9
01/04/94	58.0	1.0	98.3	1.0	1.0	----	210.0	1.0	99.5	1200.0	1.5	99.9
02/09/94	90.0	1.0	98.9	1.0	1.0	----	250.0	1.0	99.6	1200.0	2.6	99.8
03/04/94	53.0	1.0	98.1	1.0	1.0	----	200.0	1.0	99.5	1100.0	1.0	99.9
04/08/94	1.0	1.0	----	1.0	1.0	----	120.0	1.0	99.2	690.0	1.0	99.9
05/02/94	78.0	1.5	98.1	418	1.78	95.9	250.0	1.0	99.6	760.0	1.0	99.9
06/06/94	30.0	1.0	96.7	1.0	1.0	----	93.0	1.0	98.9	570.0	1.0	99.8
07/14/94	34.0	1.0	97.1	1.0	1.0	----	120.0	1.0	99.2	620.0	1.0	99.8
08/01/94	22.0	1.0	95.5	35.0	1.2	96.6	110.0	1.0	99.1	670.0	1.0	99.9
09/01/94	53.0	5.0	90.6	<100	<10	----	130.0	5.0	96.2	740.0	5.0	99.3
10/03/94	1.0	1.0	----	1.0	1.0	----	99.0	1.0	99.0	630.0	1.0	99.8
11/01/94	75.0	1.0	98.7	10.0	2.0	80.0	240.0	1.0	99.6	1300.0	1.0	99.9
12/02/94	25.0	1.0	96.0	25.0	1.0	96.0	280.0	1.0	99.6	1500.0	1.5	99.9
01/03/95	54.0	1.0	98.1	<40	1.0	----	210.0	1.0	99.5	1200.0	1.0	99.9
02/02/95	<25.0	1.0	----	<25.0	1.0	----	140.0	1.0	99.3	900.0	1.0	99.9
03/01/95	8.8	1.0	88.6	1.08	1.0	----	33.0	1.0	97.0	220.0	1.0	99.5
04/03/95	26.0	1.0	96.2	1.2	1.5 B	----	91.0	1.0	98.9	630.0	1.0	99.8
05/01/95	39.0	1.0	97.4	<25.0	1.0	----	100.0	1.0	99.0	760.0	1.0	99.9
06/01/95	13.0	1.0	92.3	108	2.28	----	35.0	1.0	97.1	240.0	1.0	99.6
07/05/95	10.0	1.0	90.0	5.4	1.0	81.5	25.0	1.0	96.0	200.0	1.0	99.5
08/03/95	9.4	1.0	89.4	3.8	1.0	73.7	24.0	1.0	95.8	210.0	1.0	99.5
09/01/95	9.4	1.0	89.4	3.3	1.1	66.7	24.0	1.0	95.8	200.0	1.0	99.5
10/02/95	9.8	1.0	89.8	1.0	1.0	----	27.0	1.0	96.3	260.0	1.0	99.6
11/01/95	10.0	1.0	90.0	2.3	1.0	56.5	28.0	1.0	96.4	230.0	1.0	99.6
12/01/95	10.0	1.0	90.0	2.2	1.0	54.5	28.0	1.0	96.4	280.0	1.0	99.6
01/02/96	22.0	1.0	95.5	8.98	1.48	84.2	60.0	1.0	98.3	520.0	1.0	99.8
<hr/>												
AVERAGES	62.4	0.9	98.6	94.8	1.6	98.3	228.8	1.3	99.4	924.3	2.4	99.7

002885