

ENTERED

FAX

To: John Kieling (505 476 6030)

From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M) Albuquerque v. Sparton Technology, Inc.

Date	No of Pages	Month
2/7/08	(3 total)	Attached is the January 2008 Monthly Report
3/5/08	"	" " " February " " "
4/5/08	"	" " " March " " "
5/8/08	"	" " " April " " "
6/7/08	"	" " " MAY " " "
7/9/08	"	" " " June " " "
8/6/08	"	" " " JULY " " "
9/6/08	"	" " " August " " "
10/7/08	"	" " " September " " "

Please call me at 719-649-1944 if you have any questions

Thanks
Tony Hurst
Project Coordinator for Sparton Technology, Inc.



HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@earthlink.net

MONTHLY PROGRESS REPORT
For month ending September 30th, 2008**CV-97-0206 (D.N.M)**
Albuquerque v. Sparton Technology, Inc.

10/07/08

Tasks Completed:**A. Groundwater Monitoring Plan**

- The evaluation of Monitoring Wells replacement needs is ongoing: includes plug and abandon MW-33 this year: continue to assess monitor wells 9, 13, 48, 53, 57 and 58 for possible abandonment or replacement. MW 53 may be deepened.
- Replaced the packers in MW-66 and MW-69 and, at the same time, sampled for the 3rd quarter GWMP.

B. Public Involvement Plan

- Working on the 5-year summary Fact sheet.

C. Deep Flow Zone System

-

D. Assessment of Aquifer Restoration

-

E. Offsite-Containment System

- The system ran 98.56% of the time and pumped 9,795,400 gallons (average of 233.7 gpm). There was six outages (total of 10.08 hours):
 - o September 9th and 12th – power outages – 4.0 hours total.
 - o September 15th for 5 hours for adjustment of the discharge pump.
 - o There were 3 short outages (1.08 hours total) to allow checking of the infiltration gallery monitoring system.

F. Source Containment System

- The system ran 96.12 % of the time and pumped 1,962,240 gallons (average of 46.7 gpm). There were 3 power outages, totaling 27.0 hours.
 - o September 8th for 0.5 hours.
 - o September 12th for 0.5 hours.
 - o September 15th for 26.0 hours.
- Metric continued with the development of a work-plan to achieve clean closure of the pond and sump area.
- A Hazardous Waste Bureau (HWB) site inspection (the ponds and the sump cap) was performed on September 15th. A potential NOV (Notice of Violation) was noted by HWB based on “failure to submit an address change (Legal Owners address) within 7 days of the effective change”. See Monthly Report “020905REP-revision1”. This remains unresolved.

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@earthlink.net

- Continued with the developing a work-plan to achieve clean closure of the pond and sump area.

G. Other

-

Tasks Planned:H. Groundwater Monitoring Plan

- Continue to evaluate Monitoring Wells replacement needs. See Annual Report Paragraph 7-2.
- The 4th quarter GWMP sampling will start on November 3rd.

I. Public Involvement Plan

- Continue work on the 5-year summary Fact sheet.
- Distribute the Fact Sheet following EPA approval. Collected names and addresses for the affected parties.

-

J. Deep Flow Zone System

-

K. Assessment of Aquifer Restoration

- Pursue approval of the 2007 (and earlier if necessary) Annual Report.

L. Offsite-Containment System

-

M. Source Containment System

- Continue the development of a work-plan to achieve clean closure of the pond and sump area.
- Resolve potential NOV from HWB.
- Determined recent proposed changes in the HWB regulations do not need responses.
- Work on the program for the CW-2 monitoring software. Determine why tone power outage was not communicated.

-

N. Other

-

O. Problems Encountered or Anticipated:

-

By:



Tony Hurst

Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)