

ENTERED

FAX

To: John Kieling (505 476 6030)


From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M) Albuquerque v. Sparton Technology, Inc.

Date	No of Pages (3 total)	Month
2/7/08	"	Attached is the January 2008 Monthly Report
3/5/08	"	" " " February " " "
4/5/08	"	" " " March " " "
5/8/08	"	" " " April " " "
6/7/08	"	" " " MAY " " "
7/9/08	"	" " " June " " "
8/6/08	"	" " " JULY " " "
9/6/08	"	" " " August " " "
10/7/08	"	" " " September " " "
11/8/08	"	" " " October " " "

Please call me at 719-649-1944 if you have any questions

Thanks
 Tony Hurst
 Project Coordinator for Sparton Technology, Inc.



HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@earthlink.net

MONTHLY PROGRESS REPORT
For month ending October 31st, 2008**CV-97-0206 (D.N.M)**
Albuquerque v. Sparton Technology, Inc.

11/08/08

Tasks Completed:

- A. Groundwater Monitoring Plan
- Continued to evaluate Monitoring Wells replacement needs. See Annual Report Paragraph 7-2.
 - The 4th quarter GWMP sampling will started on November 3rd.
- B. Public Involvement Plan
-
- C. Deep Flow Zone System
-
- D. Assessment of Aquifer Restoration
-
- E. Offsite-Containment System
- Worked on the repair of damage to the infiltration gallery solar panel and radio system that resulted from the October vandalism/robbery.
 - The system ran 91.52% of the time and pumped 9,070,100 gallons (average of 203.2 gpm). There was six outages (total of 63.06 hours):
 - o October 5th (4.08 hours), 11th (7.47 hours), and 29th (2.47 hours) – all Power outages.
 - o October 20th for 7.17 hours as a result of a low chemical feed tank.
 - o October 21st through 22nd for 35.87 hours as a result of a robbery/vandalism at the infiltration gallery.
 - o October 27th for 6.0 hours for adjustment of the discharge pump system.
- F. Source Containment System
- Continued to work on developing a work-plan to achieve clean closure of the pond and sump area.
 - Worked with the NMED on a resolution of the potential NOV from HWB.
 - Determined that recent proposed changes in the HWB regulations do not need responses.
 - Continued to work on the CW-2 monitoring software.
 - The system ran 99.21 % of the time and pumped 2,154,266 gallons (average of 48.3 gpm). There was 2 power outages, totaling 5.90 hours.
 - o October 5th for 4.5 hours.
 - o October 29th for 1.4 hours.

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@earthlink.net

G. Other***Tasks Planned:***H. Groundwater Monitoring Plan

- Continue to evaluate Monitoring Wells replacement needs. See Annual Report Paragraph 7-2.
- The 4th quarter GWMP sampling is ongoing.

I. Public Involvement Plan

- Continue work on the 5-year summary Fact sheet.
- Distribute the Fact Sheet following EPA approval. Collected names and addresses for the affected parties.

J. Deep Flow Zone SystemK. Assessment of Aquifer Restoration

- Pursue approval of the 2007 (and earlier if necessary) Annual Report.

L. Offsite-Containment System


- Complete the repair of damage to the infiltration gallery solar panel and radio system.

M. Source Containment System

- Continue the development of a work-plan to achieve clean closure of the pond and sump area.
- Complete the resolution of the potential NOV from HWB.
- Continue work on the program for the CW-2 monitoring software. Determine why the September power outage was not communicated.

N. OtherO. Problems Encountered or Anticipated:

By:



Tony Hurst
Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)