

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com

**MONTHLY PROGRESS REPORT
For month ending September 30th, 2010****CV-97-0206 (D.N.M)
Albuquerque v. Sparton Technology, Inc.**

10/06/10

Tasks Completed:

- A. Groundwater Monitoring Plan
 - Continued to evaluate Monitoring Wells replacement needs.

- B. Public Involvement Plan
 -

- C. Deep Flow Zone System
 -

- D. Assessment of Aquifer Restoration
 - Worked on plans to install permanent sampling pumps in MW-80.
 - Worked on, completed, and distributed revisions to the 2009 Annual Report.
 - EPA/NMED approved the 2009 Annual Report on Sept. 28th, 2010.
 - Installed a permanent sampling pump in MW-80 on 9/29/10.

- E. Offsite-Containment System
 - Solicited and evaluated bids for the new custom 300 gpm pump for CW-1. Ordered the pump.
 - The system ran 93.33 % of the time and pumped 8,928,800 gallons (average of 206.9 gpm). There was one outage from 9/9 to 9/11/10 for 49.0 hours. This was a result of a power outage and an associated Qwest modem communication problem.

- F. Source Containment System
 - The system ran 100.0 % of the time and pumped 1,803,100 gallons (average of 41.8 gpm).

- G. Other
 -

Tasks Planned:

- H. Groundwater Monitoring Plan
 - Continue to evaluate Monitoring Wells replacement needs.


HURST ENGINEERING SERVICES

1915 Fairfax St • Denver, CO 80220

Email: tonyhurst@q.com

- I. Public Involvement Plan
 - A Fact Sheet is being prepared (for distribution) for the period 2007 through 2009.
- J. Deep Flow Zone System
 -
- K. Assessment of Aquifer Restoration
 -
- L. Offsite-Containment System
 - Following delivery of the new 300 gpm pump for CW-1, install during the week of 10/11/10.
- M. Source Containment System
 - Continue with the development of a work-plan to achieve clean closure of the pond and sump area.
- N. Other
 -
- O. Problems Encountered or Anticipated:
 -

By:



Tony Hurst
Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)