



FAX

To: John Kieling (505 476 6030)

From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M)Albuquerque v. Sparton Technology, Inc.

Date	No of Pages	Month
2/9/11	(3 total)	Attached is the <u>January</u> 2011 Monthly Report
	(_ total)	Attached is the _____ 2011 Monthly Report
	(_ total)	Attached is the _____ 2011 Monthly Report
	(_ total)	Attached is the _____ 2011 Monthly Report
	(_ total)	Attached is the _____ 2011 Monthly Report
	(_ total)	Attached is the _____ 2011 Monthly Report
	(_ total)	Attached is the _____ 2011 Monthly Report
	(_ total)	Attached is the _____ 2011 Monthly Report
	(_ total)	Attached is the _____ 2011 Monthly Report
	(_ total)	Attached is the _____ 2011 Monthly Report
	(_ total)	Attached is the _____ 2011 Monthly Report
	(_ total)	Attached is the _____ 2011 Monthly Report
	(_ total)	Attached is the _____ 2011 Monthly Report
	(_ total)	Attached is the _____ 2011 Monthly Report
	(_ total)	Attached is the _____ 2011 Monthly Report

Please call me at 719-649-1944 if you have any questions

Thanks

Tony Hurst

Project Coordinator for Sparton Technology, Inc.

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com

**MONTHLY PROGRESS REPORT
For month ending January 31st, 2011****CV-97-0206 (D.N.M)
Albuquerque v. Sparton Technology, Inc.**

02/09/11

Tasks Completed:

- A. Groundwater Monitoring Plan
 - Continued to evaluate Monitoring Wells replacement needs.
- B. Public Involvement Plan
 -
- C. Deep Flow Zone System
 -
- D. Assessment of Aquifer Restoration
 -
- E. Offsite-Containment System
 - The system ran 99.35 % of the time and pumped 12,143,500 gallons (average of 290.5 gpm). There was two outages:
 - o An outage for 3 hours, 20 minutes occurred on January 24th and was a result of the system being brought down for flow adjustments (from 325 gpm to 319.5 gpm).
 - o The second outage for 1 hour, 14 minutes occurred on January 25th and was also a result of the system being brought down for flow adjustments (from 319.5 gpm to 299 gpm).
 - **The average flow reported for December, 2010 of 294.6 gpm was in error and the average flow in December was in fact 293.4 gpm. All other numbers were correct.**
- F. Source Containment System
 - Replaced the pipe from CW-2 pump to the ground surface.
 - Cleaned the pipeline the runs from the well to the treatment plant. Neutralized the collected waste materials with soda, and stored in a covered 300 gallon that allowed evaporation to take place.
 - Total Flow increases from 36 gpm to 48 gpm and from 48 gpm to 58 gpm resulted from the above two changes.
 - The system ran 98.43 % of the time and pumped 1,773,700 gallons (average of 42.8 gpm). There was two outages:

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com


- o An outage for 4 hours, 15 minutes occurred on January 24th as a result of the need to replace the pipe from CW-2 pump to the ground surface
- o The second outage for 6 hour, 30 minutes occurred on January 25th and was also a result of the system being brought down to allow cleaning of the pipe from the pump to the stripper, replacement of the well pipe (from the pump to ground level).

G. Other***Tasks Planned:***H. Groundwater Monitoring Plan

- Continue to evaluate Monitoring Wells replacement needs.
- Perform the 1st quarter GWMP sampling (and water level measurements) during the week of 2/7/2011.

I. Public Involvement PlanJ. Deep Flow Zone SystemK. Assessment of Aquifer RestorationL. Offsite-Containment SystemM. Source Containment SystemN. OtherO. Problems Encountered or Anticipated:

By:



Tony Hurst
Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)